

## Cost Benefit Analysis of VVIT Campus Energy Using Python

Prattipati Nagarjuna<sup>1</sup>, Akula Venkata Naresh Babu <sup>2\*</sup>, M Rama Mohan Rao<sup>3</sup>, M.MD.Ilyas<sup>4</sup>

<sup>1</sup>Assistant Professor, Dept. of EEE, Vasireddy Venkatadri Institute of Technology,  
pnagarjuna204@gmail.com

<sup>2</sup> Professor, Dept. of EEE, Vasireddy Venkatadri Institute of Technology,  
avnareshbabu@ieee.org

<sup>3</sup> Assistant Professor, Dept. of EEE, DVR & Dr HS MIC College of Technology,  
rmohan2006@gmail.com

<sup>4</sup> Dept. of EEE, Vasireddy Venkatadri Institute of Technology, maseedilyas9848@gmail.com  
\*Corresponding Author.

### ABSTRACT

The renewable energy sources take part significant role in electricity generation. The rooftop solar system is installed by domestic, industrial and commercial consumers because of its advantages. In this paper, an economic analysis has been carried out to study the financial parameters by considering different blocks realistic load of the VVIT campus. The analysis helps the consumer for effective utilization of energy resources, the opportunities for energy saving with energy efficient equipment's and to reduce the electricity tariff. A Python program has been developed for rooftop solar mathematical model to determine the different parameters for analysis like the energy consumption of different blocks with and without solar, cost benefit, payback period and reduction in CO<sub>2</sub> emissions which enables the consumers to switching from conventional energy system to rooftop solar system.

**Index Terms** – Economic Analysis, Energy Consumption, Rooftop Solar System and Python.

### 1. INTRODUCTION

The wind and solar renewable energy resources are promising for generous and ample electricity generation of the power system worldwide. A mathematical model of PV array based on particle swarm optimization and incremental conductance algorithm coordination control has been discussed to improve the output efficiency PV array [1]. A method for reactive power management has been discussed with the voltage rise and reverses power flow issues, when residential solar panels generate excess energy than the local load requirement [2]. A Genetic algorithm based optimal solution with rooftop solar photo voltaic system approach has been presented for sizing and location of the solar PV with power loss minimization as the objective for a 162 bus Kabul distribution network [3]. The two different calculation tools have presented for economic analysis of PV projects with respect to atmosphere conditions of Gulf Cooperation Council countries. One tool is the economic analysis calculator and the other tool is the solar advisory model software. Also, the significance of renewable energy costs on PV projects has been discussed [4].

A multifunctional observer based control method has been presented for grid connected solar energy system with distribution static compensator [5]. A scheme has proposed to select the best battery size and converter unit along with the location of a central battery storage system [6]. An agent based modeling by considering the social, technical, environmental and economic aspects to evaluate the diffusion of rooftop PV systems on existing buildings for different PV module technologies has discussed [7-11]. In this paper, A Python program has been developed for rooftop solar mathematical model to study the financial parameters by considering different blocks realistic load of the VVIT campus which enables the consumers to switching from conventional energy system to rooftop solar system.

## 2. MATHEMATICAL MODEL

The mathematical expressions of rooftop solar system [12] has been considered to estimate the energy consumed in a day based on the different types, rating and quantity of the loads in the VVIT campus along with number hours, the total PV generation capacity required along with the solar panels, batteries and the size of inverter. Also, the cost of solar panels, batteries, inverter and controller are considered during the cost benefit analysis. Further, the time required for the repayment of the investment i.e payback period has been estimated. Finally, the CO<sub>2</sub> emission reduction has been calculated as per the guidelines of central electricity authority. The technical, financial and environmental parameters obtained from these calculations are used to take the necessary steps as a part of green energy campus

## 3. PYTHON

In general the MATLAB has been used in many applications by electrical engineers more specific for power systems computations. The new open source language Python plays an important role in all the fields because of its simplicity, easy to learn syntax and also competitive with MATLAB. Python is a commonly used scripting language which enables engineers and researchers to solve complex problems interactively. Python is intrinsically object oriented open source language. It has strings, lists, dictionaries, functions, classes, and more as objects. These things have their own members and methods that summarize its functions and information. There are a large number of the libraries available to Python for Power System computations. The most potential modules including NumPy, SciPy, Matplotlib, Pylon, PyPower, Minpower are standard libraries used for Power System computations [13].

## 4. RESULTS AND ANALYSIS

In this section, the calculations for cost benefit analysis of rooftop solar PV system has been discussed with numerical example as VVIT campus loads. The campus has six blocks. The type of load, power rating and number of devices along with total load of block-A, B, C, D, central and new blocks are given in table I to table VI respectively. A Python code is developed to compute the count of solar panels, batteries required and also the benefit acquired in terms of money by switching to solar power. The costs of different devices are considered during the analysis from the literature [14-16] along with subsidy of 40% and the electricity tariff is Rs.6 per unit. The detailed calculations of each block are presented along with tables.

**Table I Load Details of Block-A**

| No. of Hours<br>(h) | Power Rating<br>(W) | No. of Devices | Type of Load | Total Load<br>(Wh) |
|---------------------|---------------------|----------------|--------------|--------------------|
| 8                   | 40                  | 114            | Light        | 36480              |
| 8                   | 60                  | 174            | Fan          | 83520              |
| 4                   | 1830                | 50             | AC           | 366000             |
| 4                   | 105                 | 142            | Systems      | 59640              |
| 5                   | 60                  | 16             | Laptops      | 4800               |
| 3                   | 100                 | 30             | Sockets      | 9000               |
| 8                   | 15                  | 4              | Ex-fans      | 480                |

Energy consumed in a day = 559.92 kWh

Solar panels power rating =  $559.92 / (7 \times 0.8) = 99.98 \text{ kW}$

The solar panels required =  $99.98 \times 1000 / 250 = 400$

Solar panels cost =  $(400 \times 13100) = \text{Rs } 5240000$

Total batteries required =  $559.92 \times 3 \times 1000 / (12 \times 220 \times 0.5) = 1273$

Total cost of batteries =  $1273 \times 12000 = \text{Rs } 15276000$

Size of Inverter =  $(25000 / 1.7) = 14705.88 \text{ W}$

Inverter Cost =  $(14705.88 \times 7.4) = \text{Rs } 108823.5$

Total cost of equipment =  $5240000 + 15276000 + 4500 + 108823.5 = \text{Rs } 20629323.5$   
 The total cost of equipment with subsidy =  $20629323.5 - 8251729.4 = \text{Rs } 12377594$   
 Total electricity bill without solar for 25years =  $\text{Rs } 30655620$   
 Total profit with solar power =  $30655620 - 12377594 = \text{Rs. } 18278026$   
 Payback period =  $(12377594 / 30655620) * 25 = 10.09$  years.  
 The reduction of CO<sub>2</sub> emission =  $(559.92 * 0.82 * 365 * 25) / 1000 = 4189.60$  tons

**Table II Load Details of Block-B**

| No. of Hours (h) | Power Rating (W) | No. of Devices | Type of Load | Total Load (Wh) |
|------------------|------------------|----------------|--------------|-----------------|
| 8                | 40               | 148            | Light        | 47360           |
| 8                | 60               | 155            | Fan          | 74400           |
| 4                | 1830             | 54             | AC           | 395280          |
| 4                | 105              | 93             | Systems      | 39060           |
| 5                | 60               | 11             | Laptops      | 3300            |
| 3                | 100              | 40             | Sockets      | 12000           |
| 8                | 5587             | 1              | Lift         | 44696           |
| 8                | 15               | 5              | Ex-fan       | 600             |

Energy consumed in a day =  $616.96$  kWh  
 Solar panels power rating =  $616.96 / (7 * 0.8) = 110$  kW  
 The solar panels required =  $110 * 1000 / 250 = 440$   
 Solar panels cost =  $(440 * 13100) = \text{Rs } 5764000$   
 Total batteries required =  $616.96 * 3 * 1000 / (12 * 220 * 0.5) = 1402$   
 Total cost of batteries =  $1402 * 12000 = \text{Rs } 16824000$   
 Size of Inverter =  $(25000 / 1.7) = 14705.88$  W  
 Inverter Cost =  $(14705.88 * 7.4) = \text{Rs } 108823.5$   
 Total cost of equipment =  $5764000 + 16824000 + 4500 + 108823.5 = \text{Rs } 22701323.5$   
 The total cost of equipment with subsidy =  $22701323.5 - 9080529 = \text{Rs } 13620794$   
 Total electricity bill without solar for 25years =  $\text{Rs } 33778560$   
 Total profit with solar power =  $33778560 - 13620794 = \text{Rs. } 20157766$   
 Payback period =  $(13620794 / 33778560) * 25 = 10.08$  years.  
 The reduction of CO<sub>2</sub> emission =  $(616.96 * 0.82 * 365 * 25) / 1000 = 4616.40$  tons

**Table III Load Details of Block-C**

| No. of Hours (h) | Power Rating (W) | No. of Devices | Type of Load | Total Load (Wh) |
|------------------|------------------|----------------|--------------|-----------------|
| 8                | 40               | 169            | Light        | 54080           |
| 8                | 60               | 198            | Fan          | 95040           |
| 4                | 1830             | 38             | AC           | 278160          |
| 4                | 100              | 45             | Sockets      | 18000           |
| 4                | 105              | 74             | Systems      | 31080           |
| 5                | 60               | 46             | Laptops      | 13800           |
| 4                | 3704             | 16             | Machines     | 237056          |
| 8                | 5587             | 1              | Lift         | 44696           |
| 8                | 15               | 4              | Ex-fan       | 480             |

Energy consumed in a day =  $772.39$  kWh  
 Solar panels power rating =  $772.39 / (7 * 0.8) = 137.92$  kW  
 The solar panels required =  $137.9 * 1000 / 250 = 552$   
 Solar panels cost =  $(552 * 13100) = \text{Rs } 7231200$   
 Total batteries required =  $772.39 * 3 * 1000 / (12 * 220 * 0.5) = 1755$   
 Total cost of batteries =  $1755 * 12000 = \text{Rs } 21060000$   
 Size of Inverter =  $(25000 / 1.7) = 14705.88$  W

Inverter Cost =  $(14705.88 \times 7.4) = \text{Rs } 108823.5$   
 Total cost of equipment =  $7231200 + 21060000 + 4500 + 108823.5 = \text{Rs } 28404523.5$   
 The total cost of equipment with subsidy =  $28404523.5 - 11361809.4 = \text{Rs } 17042714$   
 Total electricity bill without solar for 25 years =  $\text{Rs } 42288352$   
 Total profit with solar power =  $42288352 - 17042714 = \text{Rs } 25245638$   
 Payback period =  $(17042714 / 42288352) \times 25 = 10.07$  years.  
 The reduction of CO<sub>2</sub> emission =  $(772.39 \times 0.82 \times 365 \times 25) / 1000 = 5779.40$  tons

**Table IV Load Details of Block-D**

| No. of Hours (h) | Power Rating (W) | No. of Devices | Type of Load | Total Load (Wh) |
|------------------|------------------|----------------|--------------|-----------------|
| 8                | 40               | 125            | Lights       | 40000           |
| 8                | 60               | 158            | Fans         | 75840           |
| 4                | 1830             | 38             | AC           | 278160          |
| 5                | 105              | 6              | Systems      | 3150            |
| 4                | 723              | 17             | Machines     | 49164           |
| 5                | 60               | 76             | Laptops      | 22800           |
| 3                | 100              | 30             | Sockets      | 9000            |
| 8                | 15               | 4              | Ex-fans      | 480             |

Energy consumed in a day =  $478.59 \text{ kWh}$   
 Solar panels power rating =  $478.59 / (7 \times 0.8) = 85.46 \text{ kW}$   
 The solar panels required =  $85.46 \times 1000 / 250 = 342$   
 Solar panels cost =  $(342 \times 13100) = \text{Rs } 4480200$   
 Total batteries required =  $478.59 \times 3 \times 1000 / (12 \times 220 \times 0.5) = 1088$   
 Total cost of batteries =  $1088 \times 12000 = \text{Rs } 13056000$   
 Size of Inverter =  $(25000 / 1.7) = 14705.88 \text{ W}$   
 Inverter Cost =  $(14705.88 \times 7.4) = \text{Rs } 108823.5$   
 Total cost of equipment =  $4480200 + 13056000 + 4500 + 108823.5 = \text{Rs } 17649523.5$   
 The total cost of equipment with subsidy =  $17649523.5 - 7059809.4 = \text{Rs } 10589714$   
 Total electricity bill without solar for 25 years =  $\text{Rs } 26202802$   
 Total profit with solar power =  $26202802 - 10589714 = \text{Rs } 15613088$   
 Payback period =  $(10589714 / 26202802) \times 25 = 10.10$  years.  
 The reduction of CO<sub>2</sub> emission =  $(478.59 \times 0.82 \times 365 \times 25) / 1000 = 3581.04$  tons

**Table V Load Details of Central Block**

| No. of Hours (h) | Power Rating (W) | No. of Devices | Type of Load | Total Load (Wh) |
|------------------|------------------|----------------|--------------|-----------------|
| 8                | 40               | 126            | Lights       | 40320           |
| 8                | 60               | 130            | Fans         | 62400           |
| 6                | 1830             | 8              | AC           | 87840           |
| 6                | 105              | 44             | Systems      | 27720           |
| 6                | 60               | 10             | Laptops      | 3600            |
| 4                | 100              | 20             | Sockets      | 8000            |
| 8                | 15               | 2              | Ex-fans      | 240             |
| 6                | 10               | 66             | LEDs         | 3960            |
| 6                | 5100             | 2              | Stand AC     | 61200           |
| 2                | 5000             | 5              | Cassette AC  | 50000           |
| 6                | 4000             | 1              | Central AC   | 24000           |

Energy consumed in a day =  $369.28 \text{ kWh}$   
 Solar panels power rating =  $369.28 / (7 \times 0.8) = 65.94 \text{ kW}$   
 The solar panels required =  $65.94 \times 1000 / 250 = 264$   
 Solar panels cost =  $(264 \times 13100) = \text{Rs } 3458400$

Total batteries required =  $369.28 \times 3 \times 1000 / (12 \times 220 \times 0.5) = 839$   
 Total cost of batteries =  $839 \times 12000 = \text{Rs } 100680000$   
 Size of Inverter =  $(25000 / 1.7) = 14705.88 \text{ W}$   
 Inverter Cost =  $(14705.88 \times 7.4) = \text{Rs } 108823.5$   
 Total cost of equipment =  $3458400 + 100680000 + 4500 + 108823.5 = \text{Rs } 13639723.5$   
 The total cost of equipment with subsidy =  $13639723.5 - 5455889.4 = \text{Rs } 8183834$   
 Total electricity bill without solar for 25 years =  $\text{Rs } 20218080$   
 Total profit with solar power =  $20218080 - 8183834 = \text{Rs } 12034246$   
 Payback period =  $(8183834 / 20218080) \times 25 = 10.11 \text{ years}$ .  
 The reduction of CO<sub>2</sub> emission =  $(369.28 \times 0.82 \times 365 \times 25) / 1000 = 2763.13 \text{ tons}$

**Table VI Load Details of New Block**

| No. of Hours (h) | Power Rating (W) | No. of Devices | Type of Load | Total Load (Wh) |
|------------------|------------------|----------------|--------------|-----------------|
| 4                | 60               | 352            | Fans         | 84480           |
| 4                | 40               | 273            | Lights       | 43680           |
| 2                | 2212             | 26             | Machines     | 115024          |
| 3                | 1830             | 97             | AC           | 532530          |
| 4                | 5000             | 10             | Casette AC   | 200000          |
| 2                | 5000             | 4              | Central AC   | 40000           |
| 4                | 5000             | 3              | Stand AC     | 60000           |
| 8                | 5587             | 1              | Lift         | 44696           |
| 8                | 15               | 4              | Ex-fans      | 480             |

Energy consumed in a day =  $1120.89 \text{ kWh}$   
 Solar panels power rating =  $1120.89 / (7 \times 0.8) = 200.15 \text{ kW}$   
 The solar panels required =  $200.15 \times 1000 / 250 = 801$   
 Solar panels cost =  $(801 \times 13100) = \text{Rs } 10493100$   
 Total batteries required =  $1120.89 \times 3 \times 1000 / (12 \times 220 \times 0.5) = 2547$   
 Total cost of batteries =  $2547 \times 12000 = \text{Rs } 30564000$   
 Size of Inverter =  $(150000 / 1.7) = 88235.29 \text{ W}$   
 Inverter Cost =  $(88235.29 \times 7.4) = \text{Rs } 652941$   
 Total equipment cost =  $10493100 + 30564000 + 4500 + 652941 = \text{Rs } 41714541$   
 The total cost of equipment with subsidy =  $41714541 - 16685816 = \text{Rs } 25028725$   
 Total electricity bill without solar for 25 years =  $\text{Rs } 61368727$   
 Total profit with solar power =  $61368727 - 25028725 = \text{Rs } 36340002$   
 Payback period =  $(25028725 / 61368727) \times 25 = 10.19 \text{ years}$ .  
 The reduction of CO<sub>2</sub> emission =  $(1120.89 \times 0.82 \times 365 \times 25) / 1000 = 8387.05 \text{ tons}$

The total VVIT campus calculation has been discussed below with respect to all blocks.

Total energy consumed in a day =  $559.920 + 616.696 + 772.392 + 478.594 + 1120.89 + 369.280$   
 $= 3917.77 \text{ kWh}$   
 Solar panels power rating =  $3917.77 / (7 \times 0.8) = 699.60 \text{ kW}$   
 The solar panels required =  $699.60 \times 1000 / 250 = 2799$   
 Solar panels cost =  $(2799 \times 13100) = \text{Rs } 36666900$   
 Total batteries required =  $3917.772 \times 3 \times 1000 / (12 \times 220 \times 0.5) = 8905$   
 Total cost of batteries =  $8905 \times 12000 = \text{Rs } 106860000$   
 Size of Inverter =  $(275000 / 1.7) = 161764.70 \text{ W}$   
 Inverter Cost =  $(161764.70 \times 7.4) = \text{Rs } 1197058.78$   
 Total cost of equipment =  $36666900 + 106860000 + 4500 + 1197058.78 = \text{Rs } 144728458$   
 The total cost of equipment with subsidy =  $144728458 - 57891383 = \text{Rs } 86837075$   
 Total electricity bill without solar for 25 years =  $\text{Rs } 214498017$   
 Total profit with solar power =  $214498017 - 86837075 = \text{Rs } 127660942$

Payback period =  $(86837075/214498017) * 25 = 10.12$  years.

The reduction of CO<sub>2</sub> emission =  $(3917.77 * 0.82 * 365 * 25) / 1000 = 29314.7$  tons

The summary of the calculations are represented in Fig.1 to Fig.4. From the Fig.1, it can be observed that the New block consumes more energy and Central block consumes less energy compared to other blocks. Also, the block-C consumption is close to New block and the block-D consumption is close to Central block. Further, the block-A and block-B consumption is close to each other. Therefore, the New block electricity tariff is more and Central block tariff is less compared to other blocks as shown in the Fig.2. Similarly, From the Fig.3, it can be observed that the profit in the New block is high and the profit in the Central block is low compared to other blocks. Finally, the CO<sub>2</sub> emission reduction is high in New block and it is low in Central block compared to other blocks as shown in the Fig.4.




Fig.1 Energy Consumed with respect to Blocks




Fig.2 Electricity Tariff with respect to Blocks




Fig.3 Profits with respect to Blocks




Fig.4 CO<sub>2</sub> Emission Reduction with respect to Blocks

## 5. CONCLUSIONS

In this paper, an economic analysis has been carried out to study the financial parameters by considering different blocks realistic load of the VVIT campus. From the analysis, it can be observed that the New block consumes more energy and Central block consumes less energy compared to other blocks. Therefore, the New block electricity tariff is more and Central block tariff is less compared to other blocks. The profit and the CO<sub>2</sub> emission reduction is also more predominate in New block compared to other blocks. Finally, it can be observed that, the rooftop PV system total cost with subsidy is Rs 868.371 lakhs, along with a profit in 25 years is Rs 1276.609 lakhs. The payback period is 10.12 years with CO<sub>2</sub> emission reduction is 29314.7 tons for VVIT campus. Though the initial cost is high, switching to solar is beneficial in the long run. One more added advantage is that emission of carbon dioxide in the atmosphere is reduced considerably. The solar electric power plays a significant role in the future energy needs of Nation and the industry must take the necessary steps to make it affordable for utilities and consumers to select solar electric power compared to other forms of renewable energy sources.

## ACKNOWLEDGEMENTS

The authors would like to thank the VVIT management for the financial support to the project. Also, the authors would like to extend sincere thanks to Dr.Y.Pradeep Kumar and Charan Teja of IIT,Hyderabad for their technical support and cooperation throughout the project.

## REFERENCES

1. J. Liu, J. Li, J. Wu and W. Zhou (2017), "Global MPPT algorithm with coordinated control of PSO and INC for rooftop PV array," *The Journal of Engineering*, vol. 2017, no. 13, pp. 778-782.
2. A. Safayet, P. Fajri and I. Husain (Nov.-Dec. 2017), "Reactive Power Management for Overvoltage Prevention at High PV Penetration in a Low-Voltage Distribution System," *IEEE Transactions on Industry Applications*, vol. 53, no.6, pp.5786-5794.
3. M. Ahmadi, M. E. Lotfy, R. Shigenobu, A. Yona and T. Senjyu(2018), "Optimal sizing and placement of rooftop solar photovoltaic at Kabul city real distribution network," *IET Generation, Transmission & Distribution*, vol.12, no. 2, pp. 303-309.
4. N. Saker, A. Al-Qattan, A. Al-Otaibi and A. Al-Mulla(2018), "Cost-benefit analysis of rooftop photovoltaic Systemsbased on climate conditions of Gulf Cooperation Council countries," *IET Renewable Power Generation*, vol.12, no. 9, pp. 1074-1081.
5. P. Shah and B. Singh(Sept. 2019), "Adaptive Observer Based Control for Rooftop Solar PV System," *IEEE Transactionson Power Electronics*, vol. 35, no. 9, pp. 9402-9415.
6. P. Hasanpor Divshali and L. Söder(Jan. 2019), "Improving Hosting Capacity of Rooftop PVs by Quadratic Control of an LV-Central BSS," *IEEE Transactions on Smart Grid*, vol. 10, no. 1, pp. 919-927.
7. D. S. Schiera, F. D. Minuto, L. Bottaccioli, R. Borchellini and A. Lanzini(2019), "Analysis of Rooftop Photovoltaics Diffusion in Energy Community Buildings by a Novel GIS- and Agent-Based Modeling Co-Simulation Platform," *IEEE Access*, vol. 7, pp. 93404-93432.
8. I. K. Nisa and I. Garniwa(2019), "Integrated Energy and Economic Model for Rooftop Photovoltaics on Distribution System," *2<sup>nd</sup> International Conference on High Voltage Engineering and Power Systems (ICHVEPS)*, Denpasar, Bali, Indonesia, pp.108-113.
9. H. Gong, V. Rallabandi and D. M. Ionel(2019), "Load Variation Reduction by Aggregation in a Community of Rooftop PV Residences," *IEEE Power & Energy Society General Meeting (PESGM)*, Atlanta, GA, USA, pp.1-4.
10. Shilpa N and Sridevi HR(2019), "Optimum design of Rooftop PV System for An Education Campus Using HOMER," *Global Conference for Advancement in Technology (GCAT)*, Bangaluru, pp.1-4, India.
11. Pavan Fuke, Anil Kumar Yadav, Ipur Anil(2020), "Energy Performance and Economic Analysis of Different PV Technologies for Grid Connected Rooftop PV System", *Power India International Conference (PIICON)*, IEEE 9<sup>th</sup>, pp. 1-5.
12. Piyush Sharma, Haranath Bojja and Pradeep Yemula( March 2016) "Techno-economic analysis of off- grid RooftopsolarPVsystem," *IEEE 6<sup>th</sup> International Conference on Power Systems (ICPS)*, pp.1-5.
13. Prabakaran S(2013), "Python for Power Systems Computation," *Proceedings of 3<sup>rd</sup> National Conference on Emerging Technologies in Electrical and Electronics Engineering (NCEEE)*, pp.202-206.
14. Solar Power Energy India, "Solar Charge Controller," Available:

- <http://www.solarpowerenergyindia.com/solar-charge-controller/>
15. Urjakart, “Alpex Solar 250 Watt Panel,” Available:  
<http://www.urjakart.com/alpex-solar-250-watt-solar-panel.html>
16. CEA, “CO<sub>2</sub> Baseline Database for the Indian Power Sector,” 2015, Available:  
[http://cea.nic.in/reports/others/thermal/tpece/cdm\\_co2/user\\_guide\\_ver10.pdf/](http://cea.nic.in/reports/others/thermal/tpece/cdm_co2/user_guide_ver10.pdf/)