

Disinfectants In Potabilization Systems: Aspects For Choice And Application In Investment Plans In Tropical Countries

Rodríguez Miranda, Juan Pablo¹, Zafra Mejía, Carlos Alfonso², Rondón Quintana, Hugo Alexander³

¹*Profesor Titular. Grupo de Investigación AQUAFORMAT. Facultad del Medio Ambiente y Recursos Naturales. Universidad Distrital Francisco José de Caldas. Bogotá, Colombia. Correo electrónico:*

¹jprodriguez@udistrital.edu.co

²*Profesor Titular. Grupo de Investigación GIIAUD. Facultad del Medio Ambiente y Recursos Naturales. Universidad Distrital Francisco José de Caldas. Correo electrónico:*

²czafra@udistrital.edu.co

³*Profesor Titular. Grupo de Investigación Estudios en Pavimentos y Materiales Sostenibles. Facultad del Medio Ambiente y Recursos Naturales. Universidad Distrital Francisco José de Caldas. Correo electrónico:*

³harondonq@udistrital.edu.co

Abstract

This article considers aspects and elements for the selection of the appropriate technology for the application of integrated disinfectants to water treatment systems in tropical countries, where the vast majority of these are developing countries and the economic resources for investment are scarce. Given the above, the criteria of maximum flow rate per unit, contact time of the disinfectant, applied dose, application pH within the contact tank, area occupied by the unit, investment, operation and maintenance costs, are some explicit indicators in the choice of the appropriate technology, to guarantee the reliability, complexity and flexibility of disinfectants to eliminate pathogenic microorganisms, more convenient and implicitly in the drinking water treatment system, which adapts to climatic variability in tropical countries

Keywords: *purification, disinfectants, tropical countries*

1 Introduction:

In water treatment plants, for the treatment of raw surface or ground water, the use of disinfection for the elimination of pathogenic microorganisms is essential to deliver water suitable for human consumption and other activities. However, several factors implicitly influence the disinfection operation, which can be: the reaction contact time, the dose and the applied pH, the treatment flow rate, the amount of pathogenic microorganisms, the by-products derived from disinfection and other characteristics of previously filtered raw water. (Hoque, 1995; Petterson, 2015; Solis, 2020; Nawrocki, 2006; McDermott, 2019; Durmish, 2015).

Currently, there are several types of disinfectants, which can be physical or chemical, which can be selected according to economic and technical conditions, in the context of the drinking water treatment system, which must guarantee the total elimination of pathogenic microorganisms, with extensive areas or with adequate investment, operation and maintenance costs, not to mention technical aspects of the application of disinfectants, which influence appropriate technologies in tropical countries. Due to the above, this article considers some elements for the selection of disinfectants applied in the purification of water, according to characteristics of the filtered raw water, the reaction contact time, the dose and the applied pH, the treatment flow rate, the number of pathogenic microorganisms, areas, costs, among other aspects. (Durmish, 2015; Hoque, 1995).

2 Developing

In tropical countries, where there is only one season (summer) with bimodal events of the dry and rainy season, due to the influence of the intertropical convergence zone, with high humidity, with climatic phenomena such as Niño or La Niña, which are periodic, thus such as geographic and socio-economic overlapping conditions, which favors changing weather conditions on a time scale, that is, the fluctuating set of weather conditions, leads to integrating factors that determine and interact with the climate order in physical and geographic conditions that present a variation in time and space scales, thus, the modifications in the interaction between the components of the climate system are due to the temporal variations of the climate in short periods of time (years or months) or around its average state (high dependence on the amount and distribution of rainfall), known as climatic variability (Pabón, 1998; Montealegre, 2000; Izaguirre, 2010; García, 2007; Ruíz, 2016; Ortiz, 2017; Rodríguez e. a., 2017; Deago, 2020).

In accordance with the above, in tropical countries, where the majority are in the process of development, investments in drinking water treatment systems have reduced economic resources, therefore, it is significant to properly select treatment units and, in this case, disinfection. In general, disinfection can be carried out using physical agents such as ultraviolet radiation, ozone, heating to a boiling point, ultrasound or ultrasonic waves, among others; when a chemical is used, it can be from halogenated compounds as bromine, iodine, chlorine, and metal ions such as silver, copper and mercury, among others. Usually, the use of Chlorine can be through presentations of chlorine dioxide, chlorinated lime, sodium hypochlorite, calcium hypochlorite and chlorine gas. (AWWA, 1990; McGhee, 1999.)

Pre-chlorination can be mentioned in the disinfection of water through chlorination, which is the addition of chlorine to raw water, before any process or operation in purification, to reduce organic load, odor, taste and improve the coagulation process, however, it increases the generation of trihalomethanes (HTMs) and other halogenated organic compounds. Post chlorination is the dosage of chlorine after the filtration of particles in the water and is carried out in a chlorine contact tank, so the water is later distributed in the drinking water distribution of trihalomethanes (HTMs) and other halogenated organic compounds system. Superchlorination is the application of an additional dose of chlorine in the water distribution system to ensure the concentration of free residual chlorine throughout the system. Dechlorination is the decrease of chlorine through aeration, activated carbon, reducing agents (sulfur dioxide, bisulfites, sulfites or thiosulfites) among others. Hypochlorination is the application of compounds such as calcium or sodium hypochlorite. (Kiely G., 1999; McGhee, 1999.)

It is significant to consider the reliability, complexity and flexibility, in terms of raw water quality, capacity, process stability, and appropriate adaptability to the conditions of the purification system. Given the above, some elements for the selection of disinfectants are mentioned in Table 1. (Arboleda, 2000; Carrión, 1992; Richter, 1984; Droste, 1997; Pérez, 1997; Romero, 2000; McDermott, 2019).

Applied Disinfectant	Flow (L/s)	Contact time (Min)	Dose (mg/L)	pH	Area	Investment Cost (USD \$)	Operation and Maintenance Cost (USD \$)
<i>Applications</i>							
Prechlorination	≥ 0.1	1 - 5	0.1 - 1.0	6.0 - 7.5	LOW	AVERAGE	AVERAGE
Postchlorination	≥ 0.1	1 - 5	0.2 - 4.0	6.0 - 7.5	LOW	AVERAGE	AVERAGE
Superchlorination	≥ 0.1	1 - 5	0.2 -	6.0 -	LOW	AVERAGE	AVERAGE

			0.5	7.5			
<i>Physicists</i>							
Ultraviolet	≥ 0.1	0.25	≥ 0.001	N/A	LOW	HIGH	HIGH
Ozone	≥ 0.1	4	≥ 0.1	N/A	LOW	HIGH	HIGH
Heating	≥ 0.1	≤ 60	≥ 0.1	N/A	HIGH	HIGH	HIGH
Ultrasound	≥ 0.1	≤ 60	≥ 0.1	N/A	LOW	HIGH	HIGH
<i>Chemicals</i>							
Bromine	≥ 0.1	20 - 30	≥ 0.5	6.0 - 8.5	LOW	AVERAGE	AVERAGE
Iodine	≥ 0.1	20 - 30	1.0 - 2.0	6.5 - 8.0	LOW	AVERAGE	AVERAGE
Silver	≥ 0.1	20 - 30	≥ 0.01	6.0 - 8.5	LOW	AVERAGE	AVERAGE
Copper and Mercury	≥ 0.1	≤ 20	≥ 0.001	6.0 - 8.0	LOW	AVERAGE	AVERAGE
Gaseous Chlorine	≥ 10	≤ 20	0.4 - 4.0	6.0 - 7.5	LOW	AVERAGE	HIGH
Chlorine dioxide	≤ 10	≤ 20	≤ 1.2	6.0 - 7.5	LOW	AVERAGE	AVERAGE
Chlorinated lime	≤ 10	≤ 20	≤ 1.0	6.0 - 7.5	LOW	LOW	LOW
Sodium hypochlorite	≤ 10	≤ 20	0.4 - 4.0	6.0 - 7.5	LOW	LOW	LOW
Calcium hypochlorite	≤ 10	≤ 20	0.4 - 4.0	6.0 - 7.5	LOW	LOW	LOW

Table 1. Disinfectant selection criteria. Source: Authors.

It is significant to mention that in the selection of the disinfectant in the drinking water treatment systems, aspects such as: consumption of electrical energy, available area per unit, variability in the quality of raw water, sensitivity analysis for flow rates, low investment, operation and maintenance cost, little environmental impact, industrial safety measures, generation of by-products, not very specialized personnel for the operation and coordination with the complete purification project, among other aspects must be taken into account. (Arboleda, 2000; Arceivala D.J., 1981; Droste, 1997; Fair, 2006; Nawrocki, 2006; McDermott, 2019).

3 Conclusions

The most convenient alternative in the selection of the disinfectant in the drinking water treatment systems is the one that adapts to the climatic variability in tropical countries, the instability of the supply source in terms of the quality of the filtered raw water and therefore the conditions of tractability, to the investment conditions by the government entity, to the threshold of operation and maintenance costs, to the possibility of inclusion in conventional or advanced purification systems, mobile or portable or fixed (≤ 10 L/s) or in modular masonry plants (≥ 10 L/s). Additionally, the appropriate technology selected of the disinfectants in drinking water treatment systems must take into account the electrical energy required, the degree of complexity, local participation in design, materials, reliability and flexibility in operation technique.

4 Acknowledgment

The authors thank Francisco José de Caldas District University for the full support in the development of

this research, this being a product generated from it

References

1. Arboleda, J. (2000). Teoría y práctica de la purificación del agua. Bogotá Colombia: ACODAL.
2. Arceivala D.J., (1981). Wastewater Treatment and Disposal: Engineering and Ecology in Pollution control. New York: Marcel Dekker Inc.
3. Bharti, S. (2019). A critical review on flocculants and flocculation. Non-Metallic Material Science, Volume 01, Issue 01, April, 11 - 21 pp. .
4. Carrión, J. (1992). MEJORAMIENTO DE CALIDAD DEL AGUAPARA CONSUMO HUMANO. LIMA: OPS/CEPIS.
5. Choque, e. a. (2020). Optimization of the flocculating capacity of natural coagulants in water treatment. Revista Dyna, Vol 85. No 212. 90 - 95 pp.
6. Deago, e. a. (2020). SAR-COV2 IN TROPICAL COUNTRIES: EPIDEMIOLOGICAL, ENVIRONMENTAL AND ECONOMIC INTERACTION, CASE STUDY COLOMBIA (SOUTH AMERICA). Journal of Xi'an University of Architecture & Technology, Volume XII, Issue IV, 1833- 1843.
7. Droste, R. (1997). Theory and practice of water and wastewater treatment. New York: John Wiley & Sons Inc.
8. Fair, e. a. (2006). Abastecimiento de agua y remoción de aguas residuales. Mexico: Limusa.
9. García, M. (2007). La gestión integrada de los recursos hídricos como estrategia de adaptación al cambio climático. Ingeniería y Competitividad, 19 - 29.
10. Govorova, Z. (2020). Study of efficiency of mechanical and contact flocculation tanks. IOP Conf. Series: Materials Science and Engineering, Vol 775. 20- 25 pp.
11. Izaguirre, C. (2010). Estudio de la variabilidad climática de valores extremos de oleaje. Tesis doctoral. Cantabria, España: Universidad de Cantabria. Departamento de Ciencias y Técnica del Agua y del Medio Ambiente.
12. Li, e. a. (2020). Preparation, Performances, and Mechanisms of Microbial Flocculants for Wastewater Treatment. International journal of environmental research and public health, Vol 17. 2- 20 pp.
13. Montealegre, J. (2000). Variabilidad climática interanual asociada al ciclo El Niño- La Niña oscilación del Sur y efecto en el patron pluviométrico de Colombia. Meteorología Colombiana, 7 - 21.
14. Ortiz, e. a. (2017). Climatic Variability Patterns Associate to Water Resource Management Systems. International Journal of Applied Engineering Research, Volume 12, Number 20. 10043-10056 pp.
15. Pabón, D. (1998). Colombia en el ambiente global. Instituto de Hidrología, Meteorología y Estudios. Bogotá: IDEAM.
16. Pérez, J. (1997). Manual de Potabilización del agua. 3 Edición. Medellin: Universidad Nacional de Colombia.
17. Richter, C. (1984). Sistemas de floculación acelerada. Bogota: Asociacion Colombiana de Ingenieria Sanitaria y Ambiental.
18. Rodríguez, e. a. (2017). Planificación y gestión de los recursos hídricos: una revisión de la importancia de la variabilidad climática. Logos, ciencia y tecnología. , Vol. 9, No. 1, Julio - Diciembre. 100 -105 pp.
19. Romero, J. (2000). Purificación del agua. . Bogotá: Escuela Colombiana de Ingeniería.
20. Ruíz, e. a. (2016). Integration of the Stationality Climate Variability to a Model of Hidric Environmental Planning. International Journal of ChemTech Research, Vol.9, No.12. 278-284 pp.
21. Shi, e. a. (2019). Modeling of Flocculation and Sedimentation Using Population Balance Equation. Journal of Chemistry, Volume 2019, Article ID 9187204, 1- 10 pp.